CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/BTR/W.No.14/CSR-08/108g/SAND-Gradation/2016-17 : 04.08.2016

TEST REPORT ON DETERMINATION GRADATION OF FINE AGGREGATES

*** Customer** : **Asst. Executive Engineer,** T. Dasarahalli Sub Division, BBMP, Bangalore.

*** Agency** : **Mr. B.T. Ravikumar,**
No.180, 3rd Main, H.V.R. Layout, Magadi Road, Bangalore – 560 079.

*** Name of Work** : Improvements to Road, Drain, Foot path 12th, 19th and 20th cross Left side Bagalagunte in Ward No.14, BBMP, Bangalore.

Reference : BBMP/DZ/AEE/TDSD/PR/132/2016-17 Dated: 02.08.2016

Technical Reference : IS : 2386 Part 1 - 1963 RA-2007

Sample ID : Fine Aggregates

Sample Received on : 02.08.2016

Date of Testing : 04.08.2016

CIVIL ENGINEERING TESTING LABORATORY www.civiltechconsultants.com

Total Wt. of Aggregates in gms **1000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2007)			
		Zone-I	Zone-II	Zone-III	Zone-IV
10	100	100	100	100	100
4.75	93.50	90-100	90-100	90-100	95-100
2.36	75.70	60-95	75-100	85-100	95-100
1.18	54.50	30-70	55-90	75-100	90-100
600 Micron	25.90	15-34	35-59	60-79	80-100
300 Micron	10.50	5-20	8-30	12-40	15-50
150 Micron	4.00	0-10	0-10	0-10	0-15

*Information is furnished by the Customer/Representative.

Civil Tech Consultants & Engineers Bangalore

Remarks : This sample is under Zone-I specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

ಮುಖ್ಯ ಆಡಳಿತಾಧಿಕಾರಿಯವರ ಆದೇಶದಂತೆ
ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಿಬಿಎಂಪಿ, ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com